

Fire Safety Plan

(No Fire Alarm System):

Fire Safety Plan - No Fire Alarm System for:

(Business Name)

(Business Address)

The reproduction or use of this fire safety plan for non-commercial purposes is permitted and encouraged. Permission to reproduce the plan for commercial purposes must be obtained from Wasaga Beach Fire Department.

Table of Contents

Topic

Part 1	Introduction
Part 1 (a)	Revisions & Amendments
Part 1 (b)	Persons Requiring Assistance List
Part 2 (a)	Building Resources Audit
Part 2 (b)	Human Resources Audit
Part 3	Emergency Procedures – Occupants
Part 4	Emergency Procedures – Supervisors
Part 5	Responsibilities of the Owner/Occupant
Part 6 (a)	Fire Hazards - Residential
Part 6 (b)	Fire Hazards – Commercial
Part 7	Fire Extinguishment/Control/Confinement
Part 8	Alternative Measures
Part 9	Fire Drills
Part 10	Maintenance Requirements of Building Fire And Life Safety Systems
Part 11	Building Schematics

Part 1 Introduction

The Ontario Fire Code, Div B, Section 2.8 requires the implementation of a FIRE SAFETY PLAN for this building/occupancy. The plan is to be kept in the building in an approved location.

The implementation of the Fire Safety Plan helps to ensure effective utilization of life safety features in a building to protect people from fire. The required Fire Safety Plan should be designed to suit the resources of each individual building or complex of buildings. It is the responsibility of the owner to ensure that the information contained within the Fire Safety Plan is accurate and complete.

The Fire Protection and Prevention Act Part VII, Section 28, states that in the case of an offence for contravention of the fire code, a corporation is liable to a fine of not more than \$100,000 and an individual is liable to a fine of not more than \$50,000 or imprisonment for a term of not more than one year or both.

This official document is to be kept readily available at all times for use by staff and fire officials in the event of an emergency.

The fire safety plan approved location is ____.

Division B - 2.8.2.1.(4) states: The fire safety plan shall be reviewed as often as necessary, but at intervals not greater than 12 months, to ensure that it takes account changes in the use and other characteristics of the building.

SUBMISSION PROCEDURES

At least two (2) copies of the Plan (8 ½ X 11 format) must be submitted to the Chief Fire Official. Upon approval, one copy will be returned to the author and one copy will be retained by the Fire Department.

The Chief Fire Official is to be notified regarding any subsequent changes in the approved Fire Safety Plan.

Part 2(a) Audit of Building Resources Checklist

Occupancy Type _____

Occupant Load
Occupant Load: (if applicable) _____

Access

Designated Fire Route: No Yes

Nearest Municipal Hydrant Location: _____

Private Hydrants: No Yes (Location(s)): _____

Lockbox: No Yes (Location(s)): _____

Heating Natural Gas Electric Other _____

Main Gas Shut-off: No Yes (Location(s)): _____

Main Electrical Shut-off Location: _____

Main Domestic Water Shut-off Location: _____

Sprinkler System: No Yes Type: Wet Dry Other _____

Connected to the Fire Alarm System: No Yes

Location of Sprinkler Room/Shut Off Valves: _____

Standpipe System: No Yes

Location of Shutoff/Isolation Valves: _____

Emergency Lighting

No Yes Location(s): _____

Emergency Power

No Yes Battery Generator

Generator

Diesel Natural Gas

Fuel Supply Location: _____

Transfer Switch Location: _____

Equipment Powered by Generator: _____

Extra Hazardous Area:

Is there hazardous materials on site? No Yes

If YES, please list the material and quantity:

Exits: Refer to schematics for location of exits.

Part 2(a)
Additional Information

For any additional information not already covered:



Part 2(b)
Audit of Human Resources

Business/Building Name: _____

Address: _____ Unit No. _____

Postal Code: _____ Business Phone No. _____

Business Owner: _____

Address: _____

Postal Code: _____

Phone Number(s): _____

After Hour Contacts (24 hour telephone numbers)

Manager/Supervisor: _____ Phone No. _____

Employee/Title: _____ Phone No. _____

Employee/Title: _____ Phone No. _____

Other: _____ Phone No. _____

Building Owner: _____

Address: _____

Postal Code: _____ Phone No. _____

Sprinkler Monitoring Company: _____ Phone No. _____

Part 3

Emergency Procedures for Occupants

Please take the time to review this section (1 page)

Emergency procedures signage will be affixed to the wall on each floor area.

IN CASE OF FIRE

Upon Discovery of Fire:

- Leave fire area immediately.
- Close all doors behind you.
- Alarm occupants of building. Yell “FIRE”.
- Call Wasaga Beach Fire Department at 9-1-1 (from a safe location).
- Use exit to leave the building.
- Do not use elevators.

Upon Hearing of a Fire Condition:

- Leave building via nearest exit.
- Close doors behind you.
- Do not use elevator.

Caution:

- If smoke is heavy in the corridor, it may be safer to stay in your area. Close door and place a wet towel or other object, e.g. jacket, sweater, etc. at the base of the door.
- If you encounter smoke in stairway, use an alternate exit or find refuge in nearest suite.

Remain Calm

No Fire Alarm System

Part 4

Emergency Procedures for Supervisory Staff

Please take the time to review this section (2 pages)

Upon Discovery of Fire

- Leave fire area immediately and close doors. Alert occupants.
- Alarm occupants of building. Yell “Fire”. Follow the fire alarm supervisory procedures.
- Call 9-1-1 from a safe location.
- Exit the building via the nearest exit.
- Await the arrival of Fire Department at the main entrance.

Upon Hearing of a Fire Condition

- Ensure that the other occupants have been notified of the emergency conditions.
- Notify the Wasaga Beach Fire Department of the emergency condition. Dial 9-1-1 and ask for Wasaga Beach Fire Department.
- If it is safe to do so, supervise the evacuation of all occupants, including those requiring assistance.
- Upon the arrival of the firefighters, inform the fire officer of the conditions in the building and co-ordinate the efforts of the Supervisory staff with those of the Fire Department.
- Provide access and vital information to the firefighters as to location of persons, master keys for this occupancy and service rooms, etc.


Related Duties

In general:

- Keep the doors in fire separations closed at all times.
 - Keep access to exits and EXITS, inside and outside, clear of any obstructions at all times.
 - Do not permit combustible materials to accumulate in quantities or locations that would constitute a fire hazard.
 - Promptly remove all combustible waste from areas where waste is placed for disposal, if applicable.
 - Keep access roadways, fire routes and fire department connections clear and accessible for fire department use.
 - Maintain the fire protection equipment in good operating condition at all times.
-

- Participate in fire drills. Occupants' participation should be encouraged.
 - Have a working knowledge of the building fire and life safety systems.
 - Ensure the building fire and life safety systems are in operating condition.
 - Arrange for a substitute in your absence.
 - Comply with the Ontario Fire Code.
 - In the event of any shutdown of fire and life safety systems, notify Wasaga Beach Fire Department and initiate alternative measures.
-

Emergency Procedures
Additional Information/Comments



Emergency Procedures
Special provisions for Persons Requiring Assistance
Additional Information/Comments (pg.2)

Part 5

Responsibilities of the Owner / Occupant

Please take the time to review this section (1 page)

The building owner/occupant has numerous responsibilities related to fire safety and must ensure that the following measures are enacted:

- Establishment of emergency procedures to be followed at the time of an emergency.
 - Appointment and organization of designated supervisory staff to carry out safety duties.
 - Instruction of supervisory staff and other occupants so that they are aware of their responsibilities for fire safety.
 - Holding of fire drills in accordance with the Fire Code, incorporating Emergency Procedures appropriate to the building.
 - Control of fire hazards in the building.
 - Maintenance of building facilities provided for safety of the occupants.
 - Provisions of alternate measures for safety of occupants during shut down of fire protection equipment.
 - Assuring that checks, tests and inspections as required by the Ontario Fire Code are completed on schedule and that records are retained for a minimum period of two (2) years.
 - Post and maintain at least one (1) copy of the fire emergency procedures.
 - Keep a copy of the approved Fire Safety Plan on the premises in an approved location.
 - Notification of the Chief Fire Official regarding changes in the Fire Safety Plan.
 - Ensure that the information in the Fire Safety Plan is current.
 - Designate and train sufficient alternates to replace supervisory staff during any absence.
-

Part 6(a) Fire Hazards

Please take the time to review this section (2 pages)

Residential Properties

To avoid fire hazards in the building, occupants must:

- Never put burning materials such as cigarettes and ashes into the garbage chute.
- Never dispose of flammable liquids or aerosol cans in these chutes.
- Never force cartons, coat hangers, bundles of paper into the chute because it may become blocked.
- Avoid unsafe cooking practices: deep fat frying, too much heat, unattended stoves, loosely hanging sleeves.
- Avoid careless smoking. Never smoke in bed.
- Never leave anything that may burn or cause a trip hazard in the halls, corridors and/or stairways.
- Always clean out clothes dryer lint collector before and after use.
- Do not use unsafe electrical appliances, frayed extension cords, over-loaded outlets or lamp wire for permanent wiring.

In general, occupants should:

- Know how to alarm occupants of building, know where exits are located.
 - Call Wasaga Beach Fire Department immediately (9-1-1) whenever you need assistance.
 - Know the correct address of the building.
 - Notify the building owner/property management if special assistance is required in the event of an emergency.
 - Know procedures established to implement safe evacuation. Read and follow the manufacturer's smoke alarm (and CO detector if applicable) instructions, available from building owner/property management.
 - Know the supervisory staff in your building.
 - Report any fire hazard to supervisory staff.
 - Know the stairwell designation and the crossover floors (if any).
-

Part 6(b) Fire Hazards

Commercial, Retail and Industrial Properties

A high standard of housekeeping and building maintenance is probably the most important single factor in the prevention of fire. Listed below are some specific hazards.

- Combustible material stored in non-approved areas.
- Fire and smoke barrier door not operating properly or wedged open.
- Improper storage of flammable liquids and gases.
- Defective electrical wiring and appliances, over-fusing and the use of extension cords as permanent wiring.
- Clothes dryer lint collector full or improperly vented.
- Careless use of smoking materials.
- Kitchen hoods and filters not cleaned properly/grease laden.
- Improper disposal of oily rags.

In general, occupants should:

- Know how to alarm occupants of building, know where exits are located.
 - Call Wasaga Beach Fire Department immediately (9-1-1) whenever you need assistance.
 - Know the correct address of the building.
 - Notify the building/property management if special assistance is required in the event of an emergency.
 - Know the procedures established to implement safe evacuation.
 - Know the supervisory staff in your building.
 - Report any fire hazard to supervisory staff.
 - Know stairwell designation and the crossover floors (if any).
-

Part 7

Fire Extinguishment, Control or Confinement

Please take the time to review this section (1 page)

In the event a small fire cannot be extinguished with the use of a portable fire extinguisher or the smoke presents a hazard for the operator, the door to the area should be closed to confine and contain the fire. Leave the fire area. Ensure that occupants have been made aware of the fire and that Wasaga Beach Fire Department has been notified prior to an attempt to extinguish the fire. Only those persons who are trained and familiar with extinguisher operation may attempt to fight the fire.

Suggested Operation of Portable Fire Extinguishers

Remember the (PASS)

P - Pull the safety pin

A - Aim the nozzle

S - Squeeze the trigger handle

S - Sweep from side to side (watch for fire restarting)

Never re-hang extinguishers after use. Ensure they are properly recharged by a person that is qualified to service portable fire extinguishers and that a replacement extinguisher is provided.

Keep extinguishers in a visible area without obstructions around them.

NOTE: Prior to using a K-type extinguisher, activate the kitchen extinguishing system to avoid electrocution.

Part 8

Alternative Measures for Occupant Fire Safety

Please take the time to review this section (1 page)

In the event of any shut-down of fire protection equipment systems or part thereof, in excess of 24 hours, the fire department shall be notified in writing. Occupants will be notified and instructions will be posted as to alternative provisions or actions to be taken in case of emergency. These provisions and actions must be acceptable to the Chief Fire Official.

All attempts to minimize the impact of malfunctioning equipment will be initiated. Where portions of a sprinkler system are placed out of service, service to remaining portions must be maintained, and where necessary, the use of watchmen, bull-horns, walkie talkies, etc. will be employed to notify concerned parties of emergencies. Assistance and direction for specific situations will be sought from Wasaga Beach Fire Department.

Procedures to be followed in the event of shutdown of any part of a fire protection system are as follows:

1. Notify Wasaga Beach Fire Department, dial 705-429-5281 (DO NOT USE 911). Give your name, address and a description of the problem and when you expect it to be corrected. Wasaga Beach Fire Department is to be notified in writing of shutdowns longer than 24 hours.
2. Post notices at all exits and the main entrance, stating the problem and when it is expected to be corrected.
3. Have staff of other reliable person(s) patrol the affected area(s) at least once every hour.
4. Notify Wasaga Beach Fire Department and the building occupants when repairs have been completed and systems are operational.

Note: All shutdowns will be confined to as limited an area **and** duration as possible.

Cooking operations shall be suspended until the commercial cooking fixed extinguishing system is restored.

Part 9 Fire Drills

Please take the time to review this section

Fire drills will be held at least once every ____ months to ensure efficient execution of the Emergency Procedures. Fire drill records are required to be retained for a period of one year.

FIRE DRILL RECORD

Date: _____ Time: _____

Manager/Supervisor On-Duty: _____

Staff Present:

Deficiencies Noted:

General Comments:

Part 10

Requirements of the Ontario Fire Code

Please take the time to review this section (1 page)

Check/test/inspect requirements of the Ontario Fire Code:

- To assist you in fulfilling your obligations, included is a list of the portions of the Fire Code that requires checks, inspections and/or tests to be conducted of the facilities. It is suggested that you read over this list and perform or have performed the necessary checks, inspections and/or tests for the items which may apply to your property.
- Fire Prevention Officers may check to ensure that the necessary checks, inspections and/or tests are being done, when conducting their inspections.
- This list has been prepared for purposes of convenience only. For accurate reference, the Fire Code should be consulted.

Definitions for key words are as follows:

- Check* means visual observation to ensure the device or system is in place and is not obviously damaged or obstructed
- Test* means the operation of a device or system to ensure that it will perform in accordance with its intended operation or function
- Inspect* means physical examination to determine that the device or system will apparently perform in accordance with its intended function

It is stated in the Fire Code that records of all tests and corrective measures are required to be retained for a period of two (2) years after they are made.

General Fire Protection Systems/Equipment

General

Responsibility

Doors in fire separations shall be **checked** as frequently as necessary to ensure that they remain closed.

Exit signs shall be clearly visible and maintained in a clean and legible condition.

Internally illuminated exit signs shall be kept clearly illuminated at all times, when the building is occupied.

Weekly

When subject to accumulation of combustible deposits, hoods, filters and ducts shall be **checked** weekly and be cleaned when such deposits create an undue fire hazard.

Monthly

Doors in fire separations shall be **inspected** monthly for proper operation.

Yearly

Fire dampers and fire-stop flaps shall be **inspected** annually, or based on a schedule via contractor acceptable to the Chief Fire Official.

Every chimney, flue and flue pipe shall be **inspected** annually and cleaned as often as necessary to keep them free from accumulations of combustible deposits.

Disconnect switches for mechanical air-conditioning and ventilating systems shall be **inspected** annually to establish that the system can be shut down.

Spark arresters shall be cleaned annually or more frequently where accumulations of debris will adversely affect operations. Burnt-out arresters shall be repaired or replaced.

Portable Fire Extinguishers

General

Responsibility

Each portable extinguisher shall have a tag securely attached to it showing the maintenance or recharge date, the servicing agency and the signature of the person who performed the service. _____

A permanent record containing the maintenance date, the examiner's name and a description of any work or hydrostatic **testing** carried out shall be prepared and maintained for each portable extinguisher. _____

All extinguishers shall be recharged after use or as indicated by an inspection or when performing maintenance. When recharging is performed, the recommendations of the manufacturer shall be followed. _____

Monthly

Portable extinguishers shall be **inspected** monthly. _____

Yearly

Extinguishers shall be subject to maintenance not more than one year apart or when specifically indicated by an inspection. _____

Maintenance procedures shall include a thorough examination of the three basic elements of an extinguisher:

- a) mechanical parts _____
- b) extinguishing agent _____
- c) expelling means _____

Every twelve (12) months, pump tank water, and pump tank calcium chloride base antifreeze types of extinguishers shall be recharged with new chemicals or water, as applicable. _____

Responsibility

Five (5) Years

Every five (5) years, pressurized water and carbon dioxide fire extinguishers shall be hydrostatically **tested**.

Six (6) Years

Every six (6) years, stored pressure extinguishers that require a twelve (12) year hydrostatic **test** shall be emptied and subjected to the applicable maintenance procedures.

Smoke Alarms

General

Responsibility

Ensure dwelling unit smoke alarms are maintained in operating condition.

Ensure a copy of the smoke alarm manufacturer's Maintenance instructions or approved alternative has been provided.

Ensure a Listed Smoke Alarm is installed on every level of the home and in the corridor adjacent to sleeping areas.

Interconnected Smoke Alarms

General

Interconnected smoke alarms shall be tested and maintained in operating condition in conformance with CAN/ULC-S552 "Standard for Maintenance and Testing of Smoke Alarms", and as required by this article.

Weekly

The power supply shall be checked weekly.
Records shall be kept up to six (6) months.

Monthly

The operability of the interconnected system shall be confirmed monthly, by testing at least one (1) smoke alarm using its test function, on a rotational basis.

Yearly

Where installed, each manual pull station shall be tested to ensure activation of the interconnected smoke alarms.

Standpipe Systems

Monthly

Hose cabinets shall be **inspected** monthly to ensure that the hose and equipment are in the proper position and appear to be operable.

Responsibility

Yearly

Plugs or caps on Fire Department connections shall be removed annually and the threads **inspected** for wear, rust or obstruction. Re-secure plugs or caps, wrench tight.

If plugs or caps are missing, examine the Fire Department connections for obstructions, back flush if necessary and replace plugs or caps.

Hose valves shall be **inspected** annually to ensure that they are tight and that there is no water leakage into the hose.

Standpipe hose shall be removed and re-racked annually and after use. Any worn gaskets in the couplings, at the hose valve and at the nozzle shall be replaced.

Each hose connection in a WET standpipe system shall be provided with a legible sign reading "FIRE HOSE FOR USE BY TRAINED PERSONS ONLY".

Each hose connection in a DRY standpipe system with no permanent water supply shall be provided with a legible weatherproof sign reading "DRY STANDPIPE FOR FIRE DEPARTMENT USE ONLY".

Sprinkler Systems (Wet)

<u>General</u>	<u>Responsibility</u>
Auxiliary drains shall be inspected as required to Prevent freezing.	_____
 <u>Weekly</u>	
Except for electrically supervised valves, all valves controlling water supplies to sprinklers and alarm connections shall be checked weekly to ensure that they are sealed or locked in the open position.	_____
Water supply pressure and system air or water pressure shall be checked weekly by using gauges to ensure that the system is maintained at the required operating pressure.	_____
 <u>Monthly</u>	
On all sprinkler systems, an alarm test , using the alarm test connection located at the sprinkler valve, shall be performed monthly.	_____
<u>Valves which are locked open or valves which are electrically supervised shall be inspected monthly.</u>	_____
 <u>Two (2) Months</u>	
All transmitters and water flow devices shall be tested at two (2) month intervals.	_____
 <u>Six (6) Months</u>	
Gate-valve supervisory switches and other sprinkler system supervisory devices shall be tested at six (6) month intervals.	_____

<u>Yearly</u>	<u>Responsibility</u>
Exposed sprinkler piping hangers shall be checked yearly to ensure that they are kept in good repair.	_____
Sprinkler heads shall be checked at least once per year to ensure that they are kept in good repair.	_____
Sprinkler heads shall be checked at least once per year to ensure that they are free from damage, corrosion, grease, dust, paint, or whitewash. They shall be replaced where necessary as a result of such conditions.	_____
On wet sprinkler systems, water-flow alarm test using the most hydraulically remote test connection, shall be performed annually.	_____
Sprinkler system water pressure shall be tested annually or after any sprinkler system control valve has been operated, with the main drain valve fully open, to ensure that there are no obstructions or deterioration of the main water supply.	_____
Plugs or caps on Fire Department connections shall be removed annually and the threads inspected of wear, rust or obstruction. Re-secure plugs or caps, wrench tight. If plugs or caps are missing, examine the Fire Department connection for obstructions, back flush if necessary and replace plugs or caps.	_____

Sprinkler Systems (Dry)

	<u>Responsibility</u>
<u>General</u>	
Auxiliary drains shall be inspected as required to prevent freezing.	_____
Dry-pipe valve rooms or enclosures in unheated buildings shall be checked as often as necessary when the outside temperature falls below 0° Celsius to ensure that the system does not freeze.	_____
<u>Weekly</u>	
Except for electrically supervised valves, all valves controlling water supplies to sprinklers and alarm connections shall be checked weekly to ensure that they are sealed or locked in the open position.	_____
Water supply pressure and system air or water pressure shall be checked weekly by using gauges to ensure that the system is maintained at the required operating pressure.	_____
System pressure gauges shall be checked weekly. The system shall be maintained at the required operating pressure.	_____
<u>Monthly</u>	
On all sprinkler systems, an alarm test , using the alarm test connection located at the sprinkler valve, shall be performed monthly.	_____
<u>Two (2) Months</u>	
All transmitters and water flow devices shall be tested at two (2) month intervals.	_____

ResponsibilityThree (3) Months

The priming water supply for dry pipe systems shall be **inspected** every three (3) months to ensure that the proper level above the dry pipe valve is maintained.

Six (6) Months

Gate-valve supervisory switches and other sprinkler system supervisory devices shall be **tested** at six (6) month intervals.

Yearly

Exposed sprinkler piping hangers shall be **checked** yearly to ensure that they are kept in good repair.

Sprinkler heads shall be **checked** at least once per year to ensure that they are free from damage, corrosion, grease dust, paint, or whitewash. They shall be replaced where necessary as a result of such conditions.

Sprinkler system water pressure shall be **tested** annually or after any sprinkler system control valve has been operated, with the main drain valve fully open, to ensure that there are no obstructions or deterioration of the main water supply.

Plugs or caps on Fire Department connections shall be removed annually and the threads inspected for wear, rust or obstruction. Re-secure plugs or caps wrench tight. If plugs or caps are missing, examine the Fire Department connection for obstructions, back flush if necessary and replace plugs or caps.

Dry pipe valves shall be tripped annually by means of the system test pipe, to ensure that they operate satisfactorily and that the sprinkler alarms are in operating condition. A full flow trip test, with the control valve fully open, shall be conducted at least every three (3) years.

Responsibility**Fifteen (15) Years**

Every fifteen (15) years, dry pipe systems shall be **inspected** for obstructions in the sprinkler piping and if necessary, the entire system shall be flushed of foreign material. _____

Water Supplies for Firefighting (Fire Pumps)

Daily

The temperature of pump rooms shall be **checked** daily during freezing weather.

Responsibility

Weekly

Valves controlling water supplies exclusively for fire protection systems shall be **inspected** weekly to ensure that they are fully open and sealed or locked in that position.

Fire pumps shall be started once per week at rated speed. The fire pump discharge pressure, suction pressure, lubricating oil level, operative condition of relief valves, priming water level and general operating conditions shall be **inspected**.

Internal combustion engine fire pumps shall be operated once per week for a sufficient time to bring the engine up to normal operating temperature. The storage batteries, lubrication systems and fuel supplies shall be **inspected**.

Yearly

Fire pumps shall be **tested** annually at full rated capacity to ensure that they are capable of delivering the rated flow.

Water Supplies for Firefighting (Hydrants)

<u>General</u>	<u>Responsibility</u>
Hydrants shall be readily available and unobstructed for use at all times.	_____
<u>Yearly</u>	
Hydrants shall be inspected annually after each use.	_____
Ensure hydrants are equipped with port caps secured wrench tight. The port caps shall be removed annually and inspected for wear, rust or obstructions.	_____
The hydrant barrel shall be inspected annually to ensure that no water has accumulated.	_____
The drain valve shall be inspected for operation if water is found in the hydrant barrel when main valve is closed.	_____
Hydrant waterflow shall be inspected annually and a record shall be kept.	_____

Water Supplies for Firefighting (Water Tanks)

Daily

Responsibility

Water tank heat equipment, tank enclosure and/or water temperature shall be **checked** daily during freezing weather. _____

Weekly

Water levels and air pressure in pressure tanks shall be **checked** weekly and the relief valves on the air and the water lines shall be **inspected** weekly. _____

Monthly

Water level in gravity tanks shall be **inspected** monthly. _____

Yearly

An annual **inspection** shall be made of water tanks for fire protection, tank supporting structures and water supply systems including piping, control valves, check valves, heating systems, mercury gauges and expansion joints to ensure that they are in operating condition. _____

Cathodic protection equipment in water tanks shall be **inspected** annually. _____

Two (2) Years

Water tanks shall be **checked** every two (2) years for corrosion. _____

Five (5) Years

Water tanks shall be **inspected** every five (5) years and scraped and repainted as required. _____

Smoke Shafts and Venting Equipment

Responsibility

General

Access to windows and panels required for venting floor areas and vents to vestibules permitted to be manually openable shall be kept free of obstructions, openable without keys and operable at times.

Six (6) Months

All elevators in an elevator shaft that is intended for use as a smoke shaft be **inspected** semi-annually to ensure that on activation of the fire alarm system, the elevators will return to the street floor and remain inoperative.

Yearly

A closure in an opening to the outdoors at the top of a smoke shaft, shall be **inspected** annually to ensure that it will open:

- a) manually, outside from the building _____
- b) on a signal from the smoke/heat actuated device in the smoke shaft, and; _____
- c) when a closure in an opening between a floor area and the smoke shaft opens _____

Controls for air-handling systems for venting in the event of a fire, shall be **inspected** annually to ensure that air is exhausted from each floor area to the outdoors.

Five (5) Years

Closures in vent openings into smoke shafts from each floor shall be **inspected** sequentially over a period not to exceed five (5) years.

Commercial Cooking Equipment

<u>General</u>	<u>Responsibility</u>
Commercial cooking equipment exhaust and fire protection systems shall be installed and maintained in conformance with NFPA 96, "Ventilation Control and Fire Protection of Commercial Cooking Operations".	_____
Ensure wet chemical or alkali based dry chemical portable fire extinguishers are provided to protect commercial cooking equipment and are readily available for use in an emergency.	_____
<u>Weekly</u>	
Hoods, grease removal devices, fans, ducts and other equipment shall be checked weekly and cleaned at frequent intervals, prior to surfaces becoming heavily contaminated with grease or oily sludge.	_____
<u>Six (6) Months</u>	
Inspection and servicing of the fire extinguishing system shall be made at least every six (6) months by properly trained and qualified persons in conformance with Ontario Fire Code, Section 6.8.1.1.	_____

Emergency Lighting System

<u>Daily</u>	<u>Responsibility</u>
Check pilot lights for indication of proper operation.	_____
<u>Monthly</u>	
Batteries shall be inspected monthly and maintained as per manufacturer's specifications.	_____
Ensure that battery surface is clean and dry.	_____
Ensure that terminal connections are clean, free of corrosion and lubricated.	_____
Ensure that the terminal clamps are clean and tight as per manufacturer's specifications.	_____
Emergency lighting equipment shall be tested monthly to ensure that the emergency lighting will function upon failure of the primary power supply.	_____
<u>Yearly</u>	
Emergency lighting equipment shall be tested annually to ensure that the units will provide emergency lighting for a duration equal to the design criteria under simulated power failure conditions.	_____
After completion, the charging conditions for voltage and current and the recovery period will be tested annually to ensure that the charging system is in accordance with the manufacturer's specifications.	_____

Emergency Power Systems
















	<u>Responsibility</u>
<u>General</u>	
Emergency power systems shall be inspected, tested and maintained in conformance with CSA C282, “Emergency Electrical Power Supply for Buildings”.	_____
To ensure continued reliable operation, the emergency power supply equipment shall be operated and maintained in accordance with manufacturer’s instructions.	_____
At least two (2) copies of the instruction manual shall be maintained.	_____
<u>Monthly</u>	
The emergency electrical power shall be completely tested monthly as follows:	_____
a) Simulate a failure of the normal power supply.	
b) Arrange so that:	
i) an engine generator set operates under at least 30% of the rated load for 60 minutes and;	
ii) all automatic transfer switches are operated under load.	
c) Include an inspection for correct function of all auxiliary equipment such as radiator shutter control, coolant pumps, fuel transfer pumps, oil coolers and engine room ventilation controls.	
d) Record all instrument readings associated with the prime mover and generator and a verification that they are normal.	
e) Log and report as further prescribed in the manual of instruction for operation and maintenance.	
f) Check fuel supply for sufficient quantity.	
<u>Annually</u>	
Test the generator, control panel, and transfer switch in conformance with CSA C282, “Emergency Electrical Power Supply for Buildings”.	_____

**Maintenance
Additional Comments**

Part 11- Building Schematics

Please take the time to review this page

LEGEND FOR BUILDING / UNIT FIRE EMERGENCY SYSTEM

	Pull Pin For Kitchen Fire Suppression System
	Entrance / Exit
	Hydrant
	Siamese Fire Department Connection
	Free Standing Siamese Fire Department Connection
	Valves (General)
	Identify The Type Of Valve (e.g. Shut Off Valve For Natural Gas, Sprinklers, etc.)
	Emergency Light, Battery-Powered
	Illuminated Exit Sign, Single Face
	Combined Battery-Powered Emergency Light & Illuminated Exit Sign
	Fire Extinguisher - BC Type
	Fire Extinguisher - ABC Type
	Fire Extinguisher – Water
	Hose Cabinet
	Sprinkler Riser, indicate whether Wet or Dry System

Site Plan

- Please attach Site Plan to email or send via postal mail.
(Include Legend)
-

Floor Plan

- Please attach Floor Plan to email or send via postal mail.

(Include Legend)
