

	Public Notification of Bypass, Overflow and Spill Events	Issued: 2021-08-21 Rev.: 0 Pages: 1 of 1
Wasaga Beach Wastewater Treatment Plant		

Purpose

This notification has been prepared in accordance with Environmental Compliance Approval 5669-BWJPYC issued February 5, 2021 for the Wasaga Beach Wastewater Treatment Plant. The purpose of this procedure is to notify the Public and Downstream Users that may be impacted by an overflow, bypass or spill event.

Details

Location:	River Bank- Schoonertown Bridge SE corner at Intersection of River Road W and Mosley St.
Type of Event:	<input type="checkbox"/> Overflow <input type="checkbox"/> Bypass <input checked="" type="checkbox"/> Spill
Start Date & Time:	11:00hrs on 04/01/22
End Date & Time:	15:00hrs on 04/01/22
Total Discharge Volume (m³):	43.2m ³
Cause of the Event:	Pumping Station #3- Forcemain leak. Forcemain leak caused by possible thrust block deterioration causing the leakage of raw sewage. City staff have installed a temporary sump pump into the excavation pit to pump back into the sanitary system, until contractors can make repairs to the forcemain.

If there are any questions or concerns, please contact the Ontario Clean Water Agency at 705-429-2525 during regular office hours of Monday to Friday, 8:15AM to 4:00PM.