



## Public Notification of Bypass, Overflow and Spill Events

Issued: 2024-02-24  
Rev.: 0  
Pages: 1 of 1

### Wasaga Beach Wastewater Treatment Plant

#### Purpose

This notification has been prepared in accordance with Environmental Compliance Approval 5669-BWJPYC issued February 5, 2021 for the Wasaga Beach Wastewater Treatment Plant. The purpose of this procedure is to notify the Public and Downstream Users that may be impacted by an overflow, bypass or spill event.

#### Details

<b>Location:</b>	<b>Wasaga Beach WPCP</b>
<b>Type of Event:</b>	<input type="checkbox"/> Overflow <input checked="" type="checkbox"/> Bypass <input type="checkbox"/> Spill
<b>Start Date &amp; Time:</b>	February 24, 2022 @ 1537hrs
<b>End Date &amp; Time:</b>	February 24, 2022 @ 1550hrs
<b>Total Discharge Volume (m3):</b>	18

#### Cause of the Event:

During the 14-day performance testing of tertiary disc filtration upgrade equipment at the Wasaga Beach WPCP, secondary effluent bypassed the disc filter as a result of reduced performance through the filter. The filter performance is being reviewed by the project design Consultants and supplier. OCWA has increased secondary effluent flow to the remaining filters. Secondary and UV disinfection treatment was maintained during the event.

If there are any questions or concerns, please contact the Ontario Clean Water Agency at 705-429-2525 during regular office hours of Monday to Friday, 8:15AM to 4:00PM.