

	Public Notification of Bypass, Overflow and Spill Events	Issued: 2021-08-21 Rev.: 0 Pages: 1 of 1
Wasaga Beach Wastewater Treatment Plant		

Purpose

This notification has been prepared in accordance with Environmental Compliance Approval 5669-BWJPYC issued February 5, 2021 for the Wasaga Beach Wastewater Treatment Plant. The purpose of this procedure is to notify the Public and Downstream Users that may be impacted by an overflow, bypass or spill event.

Details

Location:	Wasaga Beach WPCP
Type of Event:	<input type="checkbox"/> Overflow <input checked="" type="checkbox"/> Bypass <input type="checkbox"/> Spill
Start Date & Time:	March 7, 2023 @ 1442 hrs
End Date & Time:	March 7, 2023 @ 1442 hrs
Total Discharge Volume (m³):	< 8 m ³
Cause of the Event:	<p style="text-align: center;">During planned maintenance activities to the chemical cleaning system at the Wasaga Beach WPCP, for a brief moment (less than a minute) secondary effluent intermittently bypassed disk # 1. UV disinfection treatment was still maintained during the bypass event.</p>

If there are any questions or concerns, please contact the Ontario Clean Water Agency at 705-429-2525 during regular office hours of Monday to Friday, 8:15AM to 4:00PM.