

	<p align="center"><b>Public Notification of Bypass, Overflow and Spill Events</b></p>	<p>Issued: 2022-12-31 Rev.: 0 Pages: 1 of 1</p>
<p align="center"><b>Wasaga Beach Wastewater Treatment Plant</b></p>		

**Purpose**

This notification has been prepared in accordance with Environmental Compliance Approval 5669-BWJPYC issued February 5, 2021 for the Wasaga Beach Wastewater Treatment Plant. The purpose of this procedure is to notify the Public and Downstream Users that may be impacted by an overflow, bypass or spill event.

**Details**

<b>Location:</b>	<b>Wasaga Beach WPCP – 30 Woodland Drive</b>
<b>Type of Event:</b>	×Overflow <input type="checkbox"/> Bypass <input type="checkbox"/> Spill
<b>Start Date &amp; Time:</b>	December 31, 2022 @ 1253hrs
<b>End Date &amp; Time:</b>	December 31, 2022 @ 1335hrs
<b>Total Discharge Volume (Litres):</b>	10
<b>Cause of the Event:</b>	Due to precipitation and snow melt, secondary effluent flow rates exceeded the capabilities of the tertiary filtration equipment. UV disinfection was maintained during the partial bypass.

If there are any questions or concerns, please contact the Ontario Clean Water Agency at 705-429-2525 during regular office hours of Monday to Friday, 8:15AM to 4:00PM.